

Hydro Balance



1 GAL.

HYDRO-BALANCE



PRE-CLEAN

COIL & COMPONENT PARTS CLEANER

- H.V.A.C. System Cleaner Leaves No Residue
- Use Prior to Application of Anti-Foulant Treatment Such as Coil & Duct Spray (H-9501)

DANGER: CAUSES SEVERE SKIN BURNS AND EYE DAMAGE. FOR PROFESSIONAL USE ONLY. KEEP OUT OF REACH OF CHILDREN. SEE SIDE PANELS FOR ADDITIONAL PRECAUTIONS.

H-PC01

H-PC01

DANGER: Causes severe skin burns and eye damage.

Do not breathe mist/vapors/spray. Wash face, hands, and any exposed skin thoroughly after handling. Wear protective gloves/protective clothing/eye protection/ face protection.

FIRST AID: IF SWALLOWED: Rinse mouth. Do NOT induce vomiting. IF ON SKIN (or hair): Take off immediately all contaminated clothing. Rinse skin with water/shower. Wash contaminated clothing before reuse. IF INHALED: Remove person to fresh air and keep comfortable for breathing. IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. Immediately call a POISON CENTER/Doctor.

Store locked up. Dispose of contents and container in accordance with all local, regional, and national regulations.

Contains [CAS]: Sodium metasilicate [6834-92-0], alcohol ethoxylate [9043-30-5].



ODOR CONTROL

FULL STRENGTH

SPRAY REFILL

MIX 1 PART CLEANER TO:

4 parts water

DIRECTIONS FOR USE:


WINDOW UNITS, SMALL CENTRAL UNITS:

1. Dilute with at least 4 parts water.
2. Shut unit off.
3. Spray coil thoroughly using enough liquid to cause contamination to run off coil.
4. Turn on blower to reduce drying time.
5. Apply EVER-CLEAN COOLING COIL ANTI-FOULANT(H-9901 or H-9932) for increased indoor air quality (IAQ) protection.

COMMERCIAL SYSTEMS, AIR HANDLING UNITS: Dilute with at least 4 parts water. If possible leave air flow on during application. Spray intake side of coil with coarse spray until saturated to the run-off point (Suction of system will cause complete coil penetration). Refuse and contamination will drain as condensate. If it is not possible to leave air flow on during application, spray coil thoroughly and turn air on immediately after application.

PRE-CLEAN should also be used on other system components such as blowers, housings, baffles, condensate pans and sheet metal duct work. Remove loose lint and particulate with brush or vacuum and spray or swab solution on surfaces to be treated. Rinse or wipe contaminated cleaning solution, allow to dry thoroughly.

Apply EVER-CLEAN COOLING COIL ANTI-FOULANT(H-9901 or H-9932) for increased indoor air quality (IAQ) protection.



Made in U.S.A.
HYDRO-BALANCE CORP.
519 Huffines Blvd., Lewisville, TX U.S.A.
(800) 527-5166 (972) 394-9422
www.HydroBalance.com