## (B) HydroBalance

### H-ATC12, H-CDC06, H-FTC24, H-SLM24

# CDC Anti-Clog#1

### For Condensate Pans



#### **KEY FEATURES**

Sealed, tamper-proof housing prevents skin contact with biocide

Filter pad controls biocide for consistent, perfectly timed chemical release over three months

Weighted, so pieces stay in position, never float away

Does not clog drain ports

Low profile—fits most cooling equipment

Has been proven to control the growth of, or inactivate, Legionnaire's Disease. Bacteria in experimental laboratory conditions for (2) months when approximately 15 gallons of water flow over CDC Anti-Clog #1 Units per day.



-	Part #	QTY	Size
	H-ATC12	12	AT/C Size 2 1/8 oz
	H-CDC06	6	45 Ton Size 6 oz
	H-FTC24	24	FT/C Size 3/4 oz
	H-SLM24	24	Up to 5 Tons

<ul> <li>Directions For Use: It is a violation of Federal law to use this product in a manner inconsistent with its labeling.</li> <li>DO NOT USE IN: HUMIDIFIERS, HUMIDIFIER SECTIONS OF AIR CONDITIONING SYSTEMS OR EVAPORATOR COOLERS.</li> <li>Clean condensate pan and drain before installing unit.</li> <li>Place unit in pan, pad side down.</li> <li>In pans with drain connections, place unit under the cooling coil in the middle of pan length.</li> <li>Unit must be in contact with condensate.</li> <li>This unit is designed and approved only for use in drain pans of Air Conditioning Systems and Refrigeration Systems.</li> <li>Do Not Remove Unit Housing. Do Not Place Unit In Drain Pans Above Food Products. Replace Unit Every 3 Months.</li> </ul>	FIRST AID: Precautionary Statements -Prevention Wash face, hands and any exposed skin thoroughly after handling. Do not eat, drink or smoke when using this product. Wear protective gloves/protective clothing/eye protection/face protection. Use only outdoors or in a well-ventilated area. Do not breathe dust/fume/gas/mist/vapors/spray. Precautionary Statements - Response Specific treatment (see supplemental first aid instructions on this label). Immediately call a POISON CENTER or doctor/physician. IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. Immediately call a POISON CENTER or doctor/physician. Call a POISON CENTER or doctor/physician if you feel unwell. Wash contaminated clothing before reuse. IF ON SKIN (or hair): Remove/Take off immediately all contaminated clothing. Rinse skin with water/shower. IF INHALED: Remove victim to fresh air and keep at rest in a position comfortable for breathing. Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a POISON CENTER or doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a POISON CENTER or doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a POISON CENTER or doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a POISON CENTER or doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a POISON CENTER or doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a POISON CENTER or doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Immediately call a poistion comfortable for breathing.
	doctor/physician. IF SWALLOWED: Call a POISON CENTER or doctor/physician if you feel unwell. Rinse mouth. Do not induce vomiting.
DANGER: CORROSIVE: Harmful if swallowed. Harmful in contact with skin. Harmful if inhaled. Causes severe skin burns and eye damage.	Contains [CAS]: Urea [57-13-6], benzyl-C12-18-alkyldimethyl [68391-01-5].





HYDRO-BALANCE CORPORATION 519 HUFFINES BLVD. LEWISVILLE, TX 75056 (800) 527-5166 | (972) 394-9422 HydroBalance.com